

APPENDIX - VIII

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Date: 10-01-2025

It is certified that an inspection team headed by Dr. D. RAVI SHANKAR, MEDICAL OFFICER (Name of Officers with designation) from PRIMARY HEALTH CENTER, KONANAKUNTE, GOVERNMENT OF KARNATAKA (Name of Department/Office) inspected the GREEN VALLEY ENGLISH HIGH SCHOOL, CHUNCHAGHATTA MAIN ROAD, KONANAKUNTE, BANGALORE - 560062 (Name & Address of the School) on 10-01-2025 and found that the GREEN VALLEY ENGLISH HIGH SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of ONE YEAR.



Signature with Seal: 28/1/25.

Name: Dr. D. RAVI SHANKAR
Designation: MEDICAL OFFICER

MEDICAL OFFICER
Urban Primary Health center
Konanakute,
Bangalore-560 062

To,

GREEN VALLEY ENGLISH HIGH SCHOOL
CHUNCHAGHATTA MAIN ROAD,
KONANAKUNTE,
BANGALORE - 560062

(Name & Address of the Institution)

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 9966 | Date - 25

Office of the Joint Director
Public Health Institute
Bengaluru - 560 001

Report of Bacteriological analysis of Water/Effluent sample

Dated: 28 - 01 - 2025

Sample No.	Source & Particulars of Water Sample	Opinion					
		M.P.N Count	Plate Count	D.C Test	S.P.P	N.S.P.P	N.S.P.P & FC.
7071	Green Valley School Kowesi water	Nil	-	-	SDP	-	-
7078	Green Valley RO	11	-	neg-	-	NSPP	-

Note:
M.P.N Count:
Most probable number of Bacteria per 100ml of Water

D.C Test:
Differential Coliform test

Plate Count:
Plate Count per ml of sample

SPP:
Water is satisfactory for Potable purpose

NSPP:
Water is not satisfactory for Drinking purpose

NSPP & FC:
Water is not satisfactory for Drinking purpose and E.Coli found

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE
Bengaluru

(PTO)